

SECRET

UNITED STATES GOVERNMENT

Memorandum

ES M67- 213

TO : Chief, Real Estate & Construction
Division, OL

DATE: 16 MAR 1967

FROM : Chief, Engineering Staff, OC

SUBJECT: Power Plant, [REDACTED] Receiver Site

25X1A

attached
ILLEGIB REF: A. Memo OL 7-1588, dated 9 March 1967
B. [REDACTED] CD 67-058, dated 15 February 1967 (with Att.)
C. ENG 67-2158, dated 14 March 1967

25X1A

1. In response to Ref (A) the following information is presented.

a. The contractor should be responsible for all external connections, power and control, from the [REDACTED] switchgear plus the UPS cubicle and its interconnections.

25X1A

b. The synchroscope is part of the UPS cubicle.

c. Drawings of the UPS, including interconnection drawings, will be forwarded as soon as available from the manufacturer. The unit is not due for completion until 5 June 1967, and final drawings are expected shortly.

d. Drawings of the existing system have previously been supplied to your office; however, we feel that, since this installation is in a constant state of flux, only an on-site survey by the contractor will resolve many of these problems.

2. It is requested that the items in Ref (B) be incorporated into the scope of work with the exception of the items listed below which are being resolved through this office:

a. Battery chargers for UPS and 235 KW generators.

b. Control panels for the 235 KW generators.

3. In order to expedite the preparation of this scope of work it is suggested that any additional co-ordination required be informally conducted with [REDACTED] of this office.

25X1A

25X1A



5010-108

SECRET

GROUP 1
Excluded from automatic
downgrading and
declassification

7L 7 1830

SECRET

Chief, Engineering Staff, OC

1 3 MAR 1967

Chief, Real Estate & Construction Division, OL

Power Plant Addition and Modification at [REDACTED] Receiver
Site

25X1A

REF : Memo dtd 9 Mar 67 to C/ES/OC fr C/RECD/OL, same subject

Recent conversations between this office and your office disclosed the scope of work and accompanying drawings forwarded to us are in some cases inconsistent with the equipment which apparently exists at the site. Therefore, it is requested that drawings pertaining to the existing equipment along with a revised scope of work be supplied this office as soon as possible.

25X1A

[REDACTED]

Distribution:

- Orig. & 1 - Addressee
- 1 - OL/RECD Project
- 1 - OL/RECD/UEB Chrono

25X1A OL/RECD/UEB/[REDACTED] ded

(13 March 1967)

DMK 3/14/67

ILLEGIB

Approved For Release 2000/06/14 : CIA-RDP78-06505A000500040091-8

Approved For Release 2000/06/14 : CIA-RDP78-06505A000500040091-8

SECRET

25X1A

SUBJECT: Power Plant Addition and Modification at [REDACTED] Receiver Site

Distribution:

Orig. & 1 - Addressee

1 - OL/RECT Project

1 - OL/RECT/USC Chrome

25X1A OL/RECT/USC [REDACTED] : dcd
(8 March 1967)

SECRET